



**NOTES:**

1. CONNECTION TO WATER MAINS TO BE MADE USING MANUFACTURED TEE.
2. WHERE REQUIRED AIR RELEASE VALVES SHALL BE LOCATED WITHIN ROAD ALLOWANCE AT SAME OFFSET AS FIRE HYDRANTS.
3. BOULEVARD TO BE GRADED TO PROVIDE POSITIVE DRAINAGE AWAY FROM THE AIR RELEASE VALVE.
4. ALL VALVES, FITTINGS AND MECHANICAL RESTRAINTS TO BE C/W DENSO PASTE, DENSO MASTIC AND DENSO TAPE OR APPROVED EQUAL, APPLIED TO MANUFACTURERS RECOMMENDATIONS.

ALL DIMENSIONS IN mm UNLESS OTHERWISE SPECIFIED.

**TOWN OF BRADFORD WEST GWILLIMBURY**

**TYPICAL AIR RELEASE  
VALVE AND CHAMBER  
DIRECT BURY INSTALLATION**

SCALE:

N.T.S.

LAST REVISED:

MAY 2014

STD.DWG.

**D105**