



HYDRANT INSTALLATION

IRON TEES, WYES, CROSSES, BENDS, REDUCERS, SLEEVES& VALVES NOT IN CHAMBER

NOTES

- 1. CATHODIC PROTECTION NOT REQUIRED ON SERVICE LINES CONNECTED TO METALLIC MAIN.
- 2. FOR SERVICE LINES: STRIP INSULATION FROM CABLE AND DOUBLE OVER THE CONDUCTOR BEFORE INSERTING BETWEEN GROUND CLAMP AND SERVICE PIPE. COAT WITH MASTIC.
- 3. FOR FITTINGS: LOOP AND TIE CABLE TO NUT TO PREVENT STRAIN ON THERMITE WELD DURING BACKFILL.
- 4. ALL EXPOSED THERMITE WELDS MUST BE PROTECTED WITH A THICK COAT OF MASTIC.
- 5. ALL VALVES, FITTINGS AND MECHANICAL RESTRAINTS TO BE C/W DENSO PASTE, DENSO MASTIC AND DENSO TAPE OR APPROVED EQUAL, APPLIED ACCORDING TO MANUFACTURERS RECOMMENDATIONS IN LOCATION AS DIRECTED BY THE TOWN.
- 6. ZINC ANODE IS NOT REQUIRED ON CSA APPROVED POTABLE PLASTIC PIPING.
 ALL DIMENSIONS IN mm UNLESS OTHERWISE SPECIFIED.

TOWN OF BRADFORD WEST GWILLIMBURY

CATHODIC PROTECTION FOR VALVES NOT IN CHAMBER, IRON FITTINGS, SERVICE CONNECTION ON PVC MAINS

N.T.S.

LAST REVISED:
OCT 2014

STD.DWG.

D113