



NOTES:

1. MINIMUM RESTRAINED LENGTHS PER BWG DESIGN STANDARDS.
2. ALL VALVES, FITTINGS AND MECHANICAL RESTRAINTS TO BE C/W DENSO PASTE, DENSO MASTIC AND DENSO TAPE OR APPROVED EQUAL, APPLIED TO MANUFACTURER'S RECOMMENDATIONS.
3. CATHODIC PROTECTION PER BWG DESIGN STANDARD D113.

ALL DIMENSIONS IN mm UNLESS OTHERWISE SPECIFIED

TOWN OF BRADFORD WEST GWILLIMBURY

**RESTRAINING OF PVC WATER
MAIN AT IN LINE VALVE**

SCALE:
N.T.S.

LAST REVISED:
MAY 2014

STD.DWG.

D114