



NOTES:

1. PRESSURE REDUCING AND SUSTAINING VALVE BYPASS PIPING INSTALLED IN VERTICAL POSITION ABOVE MAINLINE PIPING.
2. ALL BENDS, JOINTS, VALVES AND CAPS ARE TO BE MECHANICALLY RESTRAINED PER BWG DESIGN STANDARD D109.
3. CATHODIC PROTECTION PER BWG DESIGN STANDARD D113.
4. ALL VALVES, FITTINGS AND MECHANICAL RESTRAINTS TO BE C/W DENSO PASTE, DENSO MASTIC AND DENSO TAPE OR APPROVED EQUAL, APPLIED TO MANUFACTURERS RECOMMENDATIONS.

ALL DIMENSIONS IN MM UNLESS OTHERWISE SPECIFIED

TOWN OF BRADFORD WEST GWILLIMBURY

PIPE CONFIGURATION AT PRESSURE REDUCING & SUSTAINING VALVE & CHAMBERS

SCALE: N.T.S.

LAST REVISED: MAY 2014

STD.DWG.

D116