



NOTES:

1. MINIMUM TRENCH WIDTH TO BE 900mm.
2. SANITARY TEST FITTINGS AND PLUGS TO BE MARKED "SAN" (BY IPEX INC. OR APPROVED EQUAL).
3. STORM TEST FITTINGS AND PLUGS TO BE MARKED "STM" (BY IPEX INC. OR APPROVED EQUAL).
4. ALL TEST FITTINGS TO BE COMPATIBLE WITH PIPE MATERIAL USED.
5. SANITARY SERVICE SHALL ALWAYS BE ON RIGHT SIDE WHEN FACING HOUSE.
6. THE SANITARY SERVICE SHALL ALWAYS BE BELOW THE STORM SERVICE.
7. ALL PIPING TO MEET OPS REQUIREMENTS.

ALL DIMENSIONS IN mm UNLESS OTHERWISE SPECIFIED

TOWN OF BRADFORD WEST GWILLIMBURY

**STANDARD SEWER SERVICE
CONNECTIONS IN COMMON TRENCH
(DOUBLE SERVICE-RESIDENTIAL)**

SCALE: N.T.S.
LAST REVISED: OCT 2014
STD.DWG.

E102