



NOTES:

1. EXCAVATION: 275mm MINIMUM DEPTH, OR AS REQUIRED. CONTRACTOR SHALL CONTACT THE TOWN IMMEDIATELY IF UNSUITABLE OR UNSTABLE SUBGRADE IS ENCOUNTERED, SUCH AS EXCESSIVE TOPSOIL, SOFT SPOTS, AND/OR ORGANIC MATTER. METHODS AND/OR MATERIAL MUST BE APPROVED BY THE TOWN PRIOR TO COMMENCING WITH WORK. SUBGRADE TO BE CONSOLIDATED AND TESTED TO 98% S.P.D. MIN.
2. GRANULAR BASE: 200mm MIN. LAYER OF 19mm CRUSHER RUN COMPACTED TO 98% STANDARD PROCTOR DENSITY MIN.
3. ASPHALT: 30mm COMPACTED DEPTH OF HOT MIX HL3A ASPHALTIC CONCRETE ON 45mm DEPTH OF HL8 ASPHALTIC CONCRETE.
4. EDGE TREATMENT: ASPHALT EDGE TO BE 45 DEGREES, TAMPED TO FORM UNIFORMLY, SMOOTH, CLEAN EDGES, WITHOUT LATERAL DEVIATIONS. SOD TO MEET AND MATCH EXISTING GRADES, WITH SMOOTH TRANSITIONS AT A MAXIMUM SLOPE OF 4:1. ALL SODDED AREAS SHALL BE 25mm BELOW THE FINISH ELEVATION OF ASPHALT. REMOVE EXCESS TOPSOIL AND SOD AS DIRECTED.
5. DRAINAGE: GRADE WALKWAY WITH A 2% CROSS-SLOPE OR AS DIRECTED ON SITE. PONDING WATER ON ASPHALT WALKWAYS WILL NOT BE ACCEPTED.
6. SODDING: ALL DISTURBED AREAS SHALL BE SODDED OVER 100mm OF TOPSOIL (LIGHTLY COMPACTED), MINIMUM WIDTH OF 900mm. REFER TO PLAN.

ALL DIMENSIONS IN mm UNLESS OTHERWISE SPECIFIED.

TOWN OF BRADFORD WEST GWILLIMBURY	
TYPICAL ASPHALT PATHWAY 2.5m WIDE	SCALE: N.T.S. LAST REVISED: JULY 2014 STD.DWG.
1102	