



| MATERIALS | |
|--|--|
| SUPPLIED BY THE TOWN OF BWG AND INSTALLED BY BUILDER | <ul style="list-style-type: none"> 1 STRAIGHT TAIL PIECE 25mm WATER METER (PREPURCHASED BY BUILDER) |
| SUPPLIED AND INSTALLED BY THE TOWN OF BWG | <ul style="list-style-type: none"> REMOTE READER AND MXU TRANSMITTER |
| SUPPLIED AND INSTALLED BY OTHERS | <ul style="list-style-type: none"> 25mm TYPE K COPPER OR CSA APPROVED PIPING ON PRIVATE SIDE OF SERVICE READ WIRE 22 GAUGE 3-4 WIRE c/w 12mm CONDUIT 1 RIGHT ANGLE METER VALVE COMPRESSION TYPE |

NOTES:

- BUILDING CONTROL VALVE TO BE COMPRESSION TYPE AND THE SAME SIZE AS INCOMING PIPE.
- INCOMING SERVICE TO BUILDING MUST BE A MINIMUM OF 25mm ϕ TYPE K COPPER OR CSA APPROVED PIPING.
- ALL PIPE WORK DONE BY CONTRACTOR/BUILDER, INCLUDING CONNECTION TO TAIL PIECE IN ACCORDANCE WITH OBC.
- WHERE THE STATIC PRESSURE EXCEEDS 550kPa (80psi) A PRESSURE REDUCING VALVE SHALL BE INSTALLED AFTER THE METER TO LIMIT THE MAXIMUM STATIC PRESSURE TO NOT MORE THAN 550kPa (80psi).
- A MINIMUM HORIZONTAL ARC OF SPACE WITH 900mm CLEARANCE REQUIRED FOR SERVICING OF THE METER.
- READ WIRE TO BE 22 GAUGE 3-4 SOLID WIRE.

ALL DIMENSIONS IN mm UNLESS OTHERWISE SPECIFIED.

TOWN OF BRADFORD WEST GWILLIMBURY

25mm RESIDENTIAL WATER METER INSTALLATION

SCALE: N.T.S.

LAST REVISED: MAY 2014

STD.DWG.

D106