



NOTES:

1. STEEL TIE ROD OR JOINT RESTRAINER GLANDS SHALL BE USED WHEN ANCHOR TEE IS NOT PRACTICAL.
2. THE STORZ COUPLING NOZZLE SHALL ALWAYS FACE CURB.
3. TRACER WIRE SHALL BE INSTALLED AT ALL HYDRANT LOCATIONS.
4. VALVE BOX IS 105mm, REGULAR STYLE, SLIDE TYPE WITH 149mm ϕ COVER.
5. CATHODIC PROTECTION AS PER BWG STANDARD D113.
6. ALL BENDS, JOINTS AND CAPS ARE TO BE MECHANICALLY RESTRAINED PER BWG DESIGN STANDARD D109.
7. ALL VALVES, FITTINGS AND MECHANICAL RESTRAINTS TO BE C/W DENSO PASTE, DENSO MASTIC AND DENSO TAPE OR APPROVED EQUAL, APPLIED ACCORDING TO MANUFACTURER'S RECOMMENDATIONS IN LOCATION AS DIRECTED BY THE TOWN.
8. PLACE FILTER FABRIC OVER CLEAR STONE MATERIAL.

ALL DIMENSIONS IN mm UNLESS OTHERWISE SPECIFIED

TOWN OF BRADFORD WEST GWILLIMBURY

HYDRANT SET WITH MECHANICALLY RESTRAINED JOINTS

SCALE: N.T.S.

LAST REVISED: NOV 2014

STD.DWG.

D108