



NOTES:

1. CHAMBER NOT TO BE LOCATED IN DRIVEWAY.
 2. CAP TO BE DRILLED FOR SLIDING VALVE BOX
 3. VALVE CHAMBER LOCATED ON PROPERTY LINE.
 4. ALL PIPES PASSING THROUGH PRE-CAST CHAMBER WALLS TO BE SEALED WITH EMBECO NON SHRINKABLE MORTAR OR EQUAL.
 5. THE TOP OF VALVE BOXES, CHAMBER COVERS SHALL BE SET FLUSH WITH FINISHED GRADE.
 6. ALL VALVES TO BE FLANGE TYPE WITH UNI-FLANGE SERIES 900 ADAPTER FLANGES OR EQUIVALENT.
 7. FITTINGS SHALL BE CATHODICALLY PROTECTED PER BWG DESIGN STANDARD D113.
 8. SUMP SHALL BE PLACED DIRECTLY BELOW MANHOLE ACCESS OPENING.
 9. EXTEND TRACER WIRE THROUGH STEPS TO TOP OF CHAMBER AND FASTEN SECURELY AS PER BWG DESIGN SPECIFICATIONS.
 10. ALL VALVES, FITTINGS AND MECHANICAL RESTRAINTS TO BE C/W DENSO PASTE, DENSO MASTIC AND DENSO TAPE OR APPROVED EQUAL, APPLIED ACCORDING TO MANUFACTURERS RECOMMENDATIONS IN LOCATIONS AS DIRECTED BY THE TOWN.
- ALL DIMENSIONS IN mm UNLESS OTHERWISE SPECIFIED

TOWN OF BRADFORD WEST GWILLIMBURY

FIRE/DOMESTIC
COMMERCIAL SERVICE
VALVE CHAMBER

SCALE: N.T.S.

LAST REVISED: MAY 2014

STD.DWG.

D111