

## NOTES:

- 1. BY-PASS MAY BE ONE PIPE SIZE SMALLER THAN METER SIZE AND MAY BE INSTALLED HORIZONTALLY.
- 2. BACKFLOW PREVENTOR SHALL BE INSTALLED DOWNSTREAM OF THE METER AND BY-PASS. A PRESSURE RELIEF VALVE OR PRESSURE SURGE TANK MUST BE INSTALLED AS REQUIRED.
- 3. INCOMING SERVICE TO CHAMBER MUST BE A MINIMUM OF 25mm TYPE K COPPER OR CSA APPROVED PIPING.
- 4. ALL PIPE WORK DONE BY CONTRACTOR/ BUILDER, INCLUDING CONNECTION TO TAIL PIECE IN ACCORDANCE WITH OBC.
- 5. WHERE THE STATIC PRESSURE EXCEEDS 550kPa (80psi) A PRESSURE REDUCING VALVE SHALL BE INSTALLED AFTER THE METER TO LIMIT THE MAXIMUM STATIC PRESSURE TO NOT MORE THAN 550kPa (80psi).

ALL DIMENSIONS IN mm UNLESS OTHERWISE SPECIFIED.

## TOWN OF BRADFORD WEST GWILLIMBURY

TYPICAL WATER METER
IN CHAMBER

N.T.S.

LAST REVISED:

MAY 2014

D119