



NOTES:

1. SILT CONTROL FENCE SHOULD BE ALIGNED WITH CONTOURS FOR SHEET OVERLAND FLOW.
2. SILT/SEDIMENT CONTROL FENCE TO BE LOCATED IN AREAS OF LOW SEDIMENT YEILD ON SLOPES THAT CONFORM TO MTO DRAINAGE MANUAL, VOLUME 2 CHART F4-3C TOPOGRAPHIC FACTOR LS BASED ON SLOPE LENGTH AND GRADIENT.
3. SILT/SEDIMENT CONTROL FENCE SHALL BE INSTALLED WITH THE FILTER MEDIA FABRIC TOED INTO THE SOIL A MINIMUM OF 300mm BY STATIC SLICING OR TRENCH METHODS WITH COMPACTION OF THE TRENCH MATERIAL MEETING 95% STANDARD PROCTOR DENSITY.
4. STEEL 'T' BAR POSTS ARE TO BE SPACED AT A MAXIMUM 2500mm ON CENTRE.
5. FROZEN GROUND CONDITIONS REQUIRE FILTER FABRIC TO BE BACKFILLED IN TRENCH WITH CLEAR STONE.
6. GEOTEXTILE FABRIC TO BE COMPRISED OF WOVEN OR NON-WOVEN U.V. STABILIZED MATERIAL.
7. FABRIC IS TO BE FOLDED OVER THE TOP OF FENCE A MINIMUM OF 300mm AND WIRE FASTENED.

ALL DIMENSIONS IN mm UNLESS OTHERWISE SPECIFIED.

TOWN OF BRADFORD WEST GWILLIMBURY

**TYPICAL SILTATION
CONTROL FENCE**

SCALE: N.T.S.

LAST REVISED:
MAY 2014

STD.DWG.

F109