



NOTES:

1. WHERE SECTIONS OF SANITARY SEWERS ARE PROVIDED WITH WATERTIGHT COVERS, VENTS WILL BE REQUIRED EVERY THIRD MAINTENANCE HOLE.
2. ELEVATION OF THE VENT OPENING SHALL BE ABOVE REGION FLOOD LINES AS DETERMINED BY THE CONSERVATION AUTHORITY AND A MINIMUM OF 1200mm ABOVE GRADE (WHICHEVER IS GREATER).
3. VENT PIPE OPENING TO BE 450mm MIN BELOW MODULOC SECTIONS.

ALL DIMENSIONS IN mm UNLESS OTHERWISE SPECIFIED.

TOWN OF BRADFORD WEST GWILLIMBURY

**TRUNK SEWER
MAINTENANCE HOLE
VENTING DETAILS**

SCALE: N.T.S.

LAST REVISED: MAY 2014

STD.DWG.

E107