



NOTES:

1. BEDDING MATERIAL SHALL BE FULLY EXTENDED AND COMPACTED AGAINST TRENCH WALLS.
2. NO MECHANICAL COMPACTION EQUIPMENT SHALL BE USED ON TOP OF PIPE PRIOR TO PLACING A MINIMUM OF 300mm COVER.

ALL DIMENSIONS IN mm UNLESS OTHERWISE SPECIFIED

TOWN OF BRADFORD WEST GWILLIMBURY

**SERVICE CONNECTION
BEDDING DETAILS**

SCALE: N.T.S.

LAST REVISED: JULY 2014

STD.DWG.

E103