



NOTES:

1. THE CONCRETE WASHOUT AREA IS NOT TO BE LOCATED WITHIN 120m OF ANY NATURAL WATERCOURSE OR WATERBODY.
2. THE CONCRETE WASHOUT SHOULD NOT BE LOCATED WITHIN 30m OF ANY STORM WATER MANAGEMENT SYSTEMS.
3. IF SITE CONSTRAINTS MAKE THE REQUIREMENTS OF NOTES 1 AND 2 INFEASIBLE, OR IF HIGHLY PERMEABLE SOILS EXIST ON SITE, THE CONCRETE WASHOUT MUST BE INSTALLED WITH AN IMPERMEABLE LINER (16mm MIN. THICKNESS) OR SURFACE STORAGE ALTERNATIVES USING PREFABRICATED CONCRETE WASHOUT DEVICES OR A LINED ABOVE GROUND STORAGE AREA SHOULD BE USED.
4. THE CONCRETE WASHOUT SHALL BE INSTALLED PRIOR TO ANY CONCRETE PLACEMENT ON SITE.
5. A SIGN SHALL BE ERECTED AT THE CONSTRUCTION SITE ENTRANCE CLEARLY IDENTIFYING THE REQUIRED USE OF THE CONCRETE WASHOUT.
6. A SIGN SHALL BE ERECTED AT THE CONCRETE WASHOUT LOCATION.
7. SIGNS PROVIDING DIRECTIONS TO THE LOCATION OF THE CONCRETE WASHOUT SHALL BE PLACED THROUGHOUT THE SITE AS NEEDED.

ALL DIMENSIONS IN mm UNLESS OTHERWISE SPECIFIED.

TOWN OF BRADFORD WEST GWILLIMBURY

TYPICAL CONCRETE WASHOUT AREA

SCALE: N.T.S.

LAST REVISED: MAY 2014

STD.DWG.

F108